

Typical Specifications

Model:	RCXII-I
Description:	Unit shall be a spun aluminum, roof mounted gravity intake ventilator.
Standard Construction:	The unit shall be of welded and bolted construction utilizing corrosion resistant fasteners. The spun aluminum components shall be constructed of heavy duty aluminum, bolted to a rigid aluminum support structure. The aluminum base shall have continuously welded curb cap corners for added strength and maximum leak protection. The unit base shall have pre-punched mounting holes for ease of installation. The spun aluminum dome shall have a rolled bead for added strength. Birdscreen constructed of 1/2" galvanized mesh shall be mounted across the full throat perimeter. The fan shall bear a permanently attached nameplate displaying model and serial number of unit for future identification.
Options and Accessories:	Optional accessories shall be provided either factory installed or field installed as detailed in the fan schedules.
Warranty:	Manufacturer's warranty shall apply for a period of 5 years. See warranty certificate for details.
Product:	Unit shall be model RCXII-I as manufactured by JencoFan of Jacksonville, Florida, a division of Soler & Palau Ventilation Group.

Typical Specifications

Model:	RCXII-R
Description:	Unit shall be a spun aluminum, roof mounted gravity relief ventilator.
Standard Construction:	The unit shall be of welded and bolted construction utilizing corrosion resistant fasteners. The spun aluminum components shall be constructed of heavy duty aluminum, bolted to a rigid aluminum support structure. The aluminum base shall have continuously welded curb cap corners for added strength and maximum leak protection. Unit base shall have pre-punched mounting holes. The spun aluminum dome shall have a rolled bead for added strength. Birdscreen constructed of 1/2" galvanized mesh shall be mounted across the full throat perimeter. The fan shall bear a permanently attached nameplate displaying model and serial number of unit for future identification.
Options and Accessories:	Optional accessories shall be provided either factory installed or field installed as detailed in the fan schedules.
Warranty:	Manufacturer's warranty shall apply for a period of 5 years. See warranty certificate for details.
Product:	Unit shall be model RCXII-R as manufactured by JencoFan of Jacksonville, FL, a division of Soler & Palau Ventilation Group.

Typical Specifications

Model:	RCXIISF-I
Description:	Unit shall be a spun aluminum, roof mounted gravity intake ventilator.
Standard Construction:	The unit shall be of welded and bolted construction utilizing corrosion resistant fasteners. The spun aluminum components shall be constructed of heavy duty aluminum, bolted to a rigid aluminum support structure. The aluminum base shall be self flashing for added strength and maximum leak protection and to eliminate the need for a roof curb. The spun aluminum dome shall have a rolled bead for added strength. Birdscreen constructed of 1/2" galvanized mesh shall be mounted across the full throat perimeter. The fan shall bear a permanently attached nameplate displaying model and serial number of unit for future identification.
Options and Accessories:	Optional accessories shall be provided either factory installed or field installed as detailed in the fan schedules.
Warranty:	Manufacturer's warranty shall apply for a period of 5 years. See warranty certificate for details.
Product:	Unit shall be model RCXIISF-I as manufactured by JencoFan of Jacksonville, Florida, a division of Soler & Palau Ventilation Group.

Typical Specifications

Model: RCXIISF-R

Description: Unit shall be a spun aluminum, roof mounted gravity relief ventilator.

Standard Construction: The unit shall be of welded and bolted construction utilizing corrosion resistant fasteners. The spun aluminum components shall be constructed of heavy duty aluminum, bolted to a rigid aluminum support structure. The aluminum base shall be self flashing for added strength and maximum leak protection and to eliminate the need for a roof curb. The spun aluminum dome shall have a rolled bead for added strength. Birdscreen constructed of 1/2" galvanized mesh shall be mounted across the full throat perimeter. The fan shall bear a permanently attached nameplate displaying model and serial number of unit for future identification.

Options and Accessories: Optional accessories shall be provided either factory installed or field installed as detailed in the fan schedules.

Warranty: Manufacturer's warranty shall apply for a period of 5 years. See warranty certificate for details.

Product: Unit shall be model RCXIISF-R as manufactured by JencoFan of Jacksonville, Florida, a division of Soler & Palau Ventilation Group.